Exhibit E


Roof and sides to be covered with #26 Galvanized Corrugated Steel Sheets.
18" Iron Body, Brass mounted Gate Valve - Inside screw. Extension stem to operate from top of levee
100 H.P. Motor - 1150 R.P.M. - Elev. Fl. 30±
18"×22" Double Suction Pump - 420 R.P.M.
Elev. 22±
Conc. Collars
Elev. 21±
Elev. 18±
Elev. 16.75
Elev. 15±
Sta. 0+62.25
Sta. 0+59.25
Sta. 0+0±
8"×8" Posts
L.W.
Datum = Elev. 0± U.S.E.D.

ISLAND RECLAMATION DISTRICT Nº 2062

A.O. STEWART, PRESIDENT

PUMPING STATION Nº 12

16.5 Ft. STATIC HEAD

Scale 1/8" = 1 Ft.

San Francisco, Calif.
Apr. 1923

F.C. Herrmann
T.W. Ransom
} Cons. Engrs.

1966.x-313.001e